


Office of  
Construction  
and Facilities  
Management

 Department of  
Veterans Affairs

Office of  
Construction  
and Facilities  
Management



## NTS



## NTS

FUEL SSO VALVE SIZE IN. [mm]	VENT SIZE IN. [mm]
1/2-1 1/2 [5-40]	3/4 [20]
2 [50]	1 [25]
2 1/2-3 [65-75]	1 1/4 [32]
4-5 [100-125]	2 [50]
6 [150]	2 1/2 [65]

3. VENT HEADER SAME SIZE AS MAIN BURNER VENT.